

Title:

The fire resistance performance of a single specimen of an uninsulated, single-acting, double-leaf doorset in accordance with BS 476: Part 22: 1987, Clause 8.

WF Report No:

170005 **Issue 3**



Prepared for:

Synergy Thrislington.

Plot A-1, Phase-1,
Industrial Estate
Mohali,
Chandigarh-160055
India

Date:

26th March 2008

Notified Body No:

0833



0249



Summary

Objective To determine the fire resistance performance of a single specimen of an uninsulated, single-acting, double-leaf doorset when tested in accordance with BS 476: Part 22: 1987, Clause 8.

Sponsor **Synergy Thrislington**, Plot A-1, Phase-1, Industrial Estate, Mohali, Chandigarh-160055. India.

Summary of Tested Specimen The doorset had overall nominal dimensions of 2600 mm high by 2290 mm wide and incorporated two door leaves of overall nominal dimensions 2557 mm high by 1115 mm wide by 44 mm thick. The doorset was of mild steel construction and incorporated a mineral fibre core of stated density 144kg/m³. The door leaf was latched and flushbolted for the duration of the test. The doorset was installed such that the door leaves opened away from the heating conditions of the test.

Test Results:

Integrity 240 minutes*


* The test duration.


The test was discontinued after a period of 240 minutes.

Date of Test 23rd January 2008

This report may only be reproduced in full. Extracts or abridgements of reports shall not be published without permission of Bodycote warringtonfire.

Signatories


Responsible Officer N. Howard* Testing Officer


Approved D. Hankinson* Technical Consultant

* For and on behalf of Bodycote **warringtonfire**.

Report Issued
Date : 26 th March 2008

Issue 3: Amendment to sponsors name from Synergy Partitions to Synergy Thrislington. (1st May 2008).

This copy has been produced from a .pdf format electronic file that has been provided by Bodycote **warringtonfire** to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of Bodycote **warringtonfire**. The original signed paper version of this report is the sole authentic version. Only original paper versions of this report bear authentic signatures of the responsible Bodycote **warringtonfire** staff.